



**OFFICE OF CIVIL SURGEON, AMRITSAR**

PHONE 0183 2211864

E-MAIL:- nrhmamritsar@gmail.com




No.SSI/CS/ASR/2023/...../2.....


DATED;...02/05/2023.

**Certificate of Cleanliness and Sanitation**

*This Is To Certify That We Have Inspected The Premises Of **AKAL ACADEMY BASARKE, AMRITSAR** On 17/04/2023 After Inspecting Their Class Rooms And Toilets. We Certify That Their Cleanliness And Sanitation is Satisfactory. Facility of portable water with R.O. is also available.*

  
Civil Surgeon, Amritsar  
2/5

  
Manager  
**AKAL ACADEMY  
BASARKE, AMRITSAR**

  
Principal  
**AKAL ACADEMY  
BASARKE  
Chheharta Sahib (Asr.)**



**TEST REPORT**

Name & Address of Customer : <b>Akal Academy Basarke P.O Gumanpura, Near Bagichiwala Bhatha</b> <b>Akal Academy Basarke P.O Gumanpura, Near Bagichiwala Bhatha</b>	Customer Reference No.	<b>No : 42/09/2022/Gen/AAB Dated : 03/11/2022</b>
	Sample Submitted by	<b>Mr.Jaswinder</b>
	Date of Sample Receipt	<b>03/11/2022</b>
	Analysis Starting Date	<b>03/11/2022</b>
	Analysis completion Date	<b>04/11/2022</b>

Discipline : <b>Chemical Testing</b>	Group: <b>Water</b>
Test Report No.: <b>RWTLASR/2223/00623</b>	Date of Issue : <b>14/11/2022</b>
Registration no.: <b>RWTLASR/REG2223/04149</b>	Condition of Sample : <b>Unsealed</b>
Source : <b>NA</b>	Quantity/Type of Bottle: <b>1000 ml / Plastic Bottles</b>
Scheme : <b>NA</b>	Location/Depth : <b>Bhatha(S/pump 425) / NA</b>
Village : <b>NA</b>	Habitation : <b>NA</b>
Block: <b>NA</b>	District : <b>Amritsar</b>
Latitude : <b>NA</b>	Longitude: <b>NA</b>

Sample Type: **Water**

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.67	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993 ) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	432	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	<b>1.51</b>	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	<b>492</b>	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	152	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	32.06	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	17.49	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	13.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.

2. The sample will be destroyed after retention time unless otherwise specified specially.

3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.

4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected

5. \* Value not available or test not performed for this parameter.

**Mr. Pankaj Kumar**  
Quality Manager  
Authorized Signatory  
For, Regional Water Testing Lab,  
Amritsar

----- End of the Test Report -----

Manager

**AKAL ACADEMY**  
**BASARKE AMRITSAR**

Page No: 1/1

Principal

**AKAL ACADEMY**  
**BASARKE**  
**Chhacharta Sahib (Asr.)**