

ਪੱਤਰ ਨੰ.....1215

ਮਿਤੀ.....22/06/2022

ਵੱਲ,

ਪ੍ਰਿੰਸੀਪਲ

ਅਕਾਲ ਅਕੈਡਮੀ ਭਾਈ ਦੇਸਾ ਸੀਨੀਅਰ ਸੈਕੰਡਰੀ ਸਕੂਲ, (ਇੰਗਲਿਸ਼ ਮੀਡੀਅਮ)

ਭਾਈ ਦੇਸਾ (ਮਾਨਸਾ)

ਵਿਸ਼ਾ:- ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਸਬੰਧੀ। (ਸਾਲ 2022-23)

ਹਵਾਲਾ:- ਆਪ ਦਾ ਪੱਤਰ ਨੰ. AABD/GFN/2022/66 ਮਿਤੀ 15/06/2022

ਤੁਹਾਡੇ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਇੰਚਾਰਜ ਵੱਲੋਂ ਨਿਰੀਖਣ ਕੀਤਾ ਗਿਆ। ਨਿਰੀਖਣ ਦੌਰਾਨ ਪਾਇਆ ਗਿਆ ਕਿ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸੇਫ ਹੈ। ਇਸ ਲਈ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਵੱਲੋਂ ਕੀਤੀ ਸਿਫਾਰਸ਼ ਨੂੰ ਮੁੱਖ ਰੱਖਦੇ ਹੋਏ 31/03/2023 ਤੱਕ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/ ਸਰਟੀਫਿਕੇਟ

ਅਤੇ ਨਕਸ਼ਾ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,

ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,

ਮਾਨਸਾ।

ਮਿਤੀ

ਪਿੱਠ ਅੰਕਣ ਨੰ.

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ, ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ ਨੰ.1, ਮਾਨਸਾ ਨੂੰ ਉਹਨਾਂ ਦੇ ਪੱਤਰ ਨੰ. 195 ਮਿਤੀ 20/06/2022 ਦੇ ਸਬੰਧ ਵਿੱਚ ਭੇਜ ਕੇ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਆਪ ਦੀ ਰਿਪੋਰਟ ਨੂੰ ਮੁੱਖ ਰੱਖਦੇ ਹੋਏ ਉਕਤ ਸਕੂਲ ਨੂੰ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,

ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,

ਮਾਨਸਾ।

Office : Executive Engineer, Provincial Mandal Lok" Mana Department Bhawan Te Marg Sakha, Mansa

Telephone Tax 01652-238104

Email ID xen.mansa@gmail.com

Letter No... 25

Date- 22/06/2022

.....
Towards

The principal

Akal Academy Bhai Desa Senior Secondary School, (English Medium)

Bhai Desa (Mansa)

Subject- Regarding Issuance building safety certificate. (Year 2022-23)

Reference:- your letter No. AABD/GFN/2022/66 dated 15/06/2022

Your school building was inspected by the Ural Engineer-in-Charge. During the inspection, it was found that the school building is safe. Therefore, school building safety certificate is issued up to 31/03/2023 keeping in mind the recommendation made by the Sub Divisional Engineer School building safety by 31/03/2023. Certificate is issued.

Attached certificate

And the map

Executive Engineer,

Provincial Board B and M. Sakha,

Mansa

Date

Back number no.

A Copy of the above, Sub-Divisional Officer, Provincial Sub-Division No. 1, it is written in relation to Mansa to his son 195 dated 20/06/2022 that the said school building safety certificate was issued keeping in mind his report.

Executive Engineer,

Provincial Board B and M. Sakha,

Mansa



ATTES-ED
SURESH KUMAR
Advocate & Notary
(Appointed by Govt. of India)
TALWANDI SARO
25 AUG 2023

Building Safety Report:


NAME OF SCHOOL:- AKAE Academy, BHAI DESA (Distt Mansa)

(District- MANSA)

As per report of 18-06-2022 Assistant/Junior Engineer on his visually inspection, the above mentioned school seems visually safe subject to the following observations and conditions.

1. The Parameters to check the stability and safety of building such as structural Design, Architectural Drawings, Bearing capacity, Foundation details, Structural drawings, Technical Specifications, Test reports of Material used and Quality control reports are not available
2. In case any addition, alteration, expansion and modification to this building are required/to be done, regarding this, inspection of undersigned may be arranged and obtained a certification after the completion from the undersigned.
3. In the case of building is affected by flood or if there is any settlement of walls foundation of roof etc. immediately inspection of the undersigned arranged to check the stability and safety of the building.
4. A separate certificate regarding Fire Fighting should be obtained from the competent Authority.
5. A separate certificate regarding Electrical works should be obtained from the competent Authority.
6. The owner of the building/Management is fully responsible regarding safety of the building from all angles in spite of this report.
7. This report is for the covered area of the school building 77474.90 sq ft which is submitted by the owner of the school building as per drawing.
8. The building of the school is constructed as framed structure/brick masonry.
9. This report is not valid for legal purpose.
10. That the fee charges for the year 2022-2023

As per visually inspection as reported by the concerned Assistant/Junior Engineer the above building may be used for normal use for One year up to 31-3-2023 Subject to the above conditions.


Assistant/Junior Engineer

Performa for the Safety of School Building
Part 1
(To be filled by the Head of the School / Institute)
2022-2023

1. Name of the School : AA BHAI DESA
2. Location : Distt: Mansa Punjab .
3. Plot Area : 42440.44SqM.m =243786.84Sq.ft.
4. Plinth Area : 7200.27 Sq m .=77474.90Sq.ft.
5. No. of Storey's : G+2
6. Year of construction of Building : 2008
7. If the Building has been constructed Under the supervision of the qualified Engineer, the following details may be Given:
 - Name of the Engineer with Qualification : **Er. Sanjeev Dua (B.E Civil)**
B.E CIVIL
 - Address of Engineer : 5A, Vijaynagar NewDelhi-110009
 - a. Set of Structural Drawing used In the construction, if available.
 - a) Name & Address of Architect : Ar Jagvinder Kaur,
The KalgidharTrust
F-178 ,Phase 8
Industrial Area ,Mohali.
SAS Nagar Punjab.
A.I.I.A CA/2017/81813
 - b) With Qualification
8. Whether the building has been Constructed for the purpose of
 - a. School : Yes
 - b. Residential purpose & converted : No
9. Material used for Roof
 - a. R.C.C. Slabs : Yes
 - b. R.S. joists & Batons : No
 - c. Wooden joist & Batons : No
10. Material used for walls
 - a. Mud Mortar : No
 - b. Cement Mortar : Yes
 - c. Plaster I) Lime Mortar : No
II) Cement Mortar : Yes
11. Flooring
 - a. Conglomerate : No
 - b. Terrazzo : No
 - c. Brick Paving : No
 - d. Cement Concrete : Yes
12. Of the room along with size and Location Of door window attached.

Jagvinder Kaur

AR. JAGVINDER KOUR
THE KALGIDHAR TRUST
F-178 / PHASE 8
INDUSTRIAL AREA, MOHALI
SAS NAGAR PUNJAB
A.I.I.A CA/2017/81813

