

PROFORMA FOR SAFE DRINKING WATER AND SANIARY CONDITIONCERTIFICATE

No...03..

Dated...02-01-2024

To

Akal Academy,
Dhamot Kalan Block Doraha,
Dist. Ludhiana.

It is certified that an inspection team headed by Er. Gaurav Kant Pathak SDE W/S & Sanitation Sub Division Doraha from Sub Division Doraha inspected the Akal Academy Dhamot Kalan Block Doraha on dated 07.11.2023 and found that that Akal Academy Dhamot Kalan has safe drinking water Facilities for the students and members of staff of the institution and is maintaining the hygienic Sanitation conditions in the school building Satisfactorily.

The above is valid for a period for one year.

Signature with Seal :..........

Name :Er. Gaurav Kanth Pathak

Designation :Sub Divisional Engineer

Name & Address of the :Sub Divisional Engineer

Office/Department :Water Supply & Sanitation

Sub Division Doraha.

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਦੋਰਾਹਾ।

Behind BDPO Office Doraha

ਫੋਨ ਨੰ.01628-501248

ਈਮੇਲ-sdekhanna02@gmail.com

ਸੇਵਾ ਵਿਖੇ

ਮਿਸ. ਬਲਜੀਤ ਕੌਰ ਪ੍ਰਿੰਸੀਪਲ,
ਅਕਾਲ ਅਕੈਡਮੀ ਧਮੋਟ ਕਲਾਂ,
ਬਲਾਕ ਦੋਰਾਹਾ ਜਿਲ੍ਹਾ ਲੁਧਿਆਣਾ।


ਨੰ. ੦੫

ਮਿਤੀ. ੦੨-੦੧-੨੦੨੪

ਵਿਸ਼ਾ:- ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਹਵਾਲਾ:- ਆਪ ਜੀ ਦਾ ਪੱਤਰ ਰੈਫ.ਨੰ.51/AA/Dhamot/2023-24 ਮਿਤੀ 30.10.2023

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਦੇ ਸਬੰਧ ਵਿੱਚ Akal Academy Dhamot Kalan ਜਿਲ੍ਹਾ ਲੁਧਿਆਣਾ ਵਿਖੇ ਜਲ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦੀ ਪ੍ਰੋਵੀਜ਼ਨ ਤਸੱਲੀ ਬਖਸ਼ ਪਾਈ ਗਈ ਹੈ। ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦਾ ਸਰਟੀਫਿਕੇਟ ਮਿਤੀ 02.01.2024 ਤੋਂ 01.01.2025 ਤੱਕ ਇੱਕ ਸਾਲ ਲਈ ਇਸ ਸ਼ਰਤ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਜੇਕਰ ਇਸ ਸਮੇਂ ਦੌਰਾਨ ਮੁੜ ਚੈਕਿੰਗ ਕਰਨ ਤੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਵਿੱਚ ਕੋਈ ਕਮੀ ਪੇਸ਼ੀ ਪਾਈ ਗਈ ਤਾਂ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਕਰਨ ਦਾ ਹੱਕ ਮਹਿਕਮੇ ਕੋਲ ਰਾਖਵਾਂ ਹੋਵੇਗਾ।


ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
Sub Divisional Engineer
Water Supply & Sanitation
Sub Division, Doraha

BLOCK WATER TESTING LABORATORY, KHANNA

Water Supply & Sanitation Division, Court Complex, Samadhi Road, Khanna, Dist. Ludhiana

bwtlkhan@gmail.com

TEST REPORT

Name & Address of Customer : Sub Divisional Engineer ,Doraha Back Side BDPO Office Doraha			Customer Reference No.		No : 930 Dated : 07/11/2023	
			Sample Submitted by		Parminder Singh	
			Date of Sample Receipt		21/12/2023	
			Analysis Starting Date		12/12/2023	
			Analysis completion Date		14/12/2023	
Discipline : Chemical Testing			Group: Water			
ULR No.:		NABLDWT0049423134F		Sample Type :		Water
Test Report No.:		BWTLKHA/2324/00138		Date of Issue :		18/12/2023
Registration no.:		BWTLKHA/REG2324/00907		Condition of Sample :		Unsealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		500 ml / Transparent Plastic Bottle
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Ro at Akal Academy.Dhamot / NA
Village :		Dhamot Kalan		Habitation :		Dhamot Kalan
Block:		Doraha		District :		Ludhiana
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.68	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	230	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	144	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	168	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	51	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	10	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method

BLOCK WATER TESTING LABORATORY, KHANNA
Water Supply & Sanitation Division, Court Complex, Samadhi Road, Khanna, Dist. Ludhiana


bwtlkhan@gmail.com

11	Chloride	24	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By



Vijay Passi
Chemist/Analyst
Authorized Signatory
For, Block Water Testing Laboratory
Khanna

----- End of the Test Report -----