

2022

**District Water Testing Laboratory,  
Water Supply and sanitation Deptt., Jalandhar.**

ID No. DWTLJAL/07

Dated 17/3/2022

**TEST REPORT  
Chemical Testing**

Sample Registration No. : DWTLJAL/07

Sample code given by customer : Not Applicable

Issued to: - AKA ACADEMY PHARMAL KARAN

**SAMPLE PARTICULARS**

Ref. Letter No. :  
Date of Receipt : 11/3/2022  
Sample code given by customer : N/A  
Name / Nature of sample : water  
Condition of the sample : unsealed  
Qty/Pkg : 75 ml  
Sampling Method : Sample not drawn by DWTLJAL  
Test Start Date : 11/3/2022  
Test Completion Date : 17/3/2022

  
Quality Manager/ Sr. Chemist  
District Water Testing Laboratory,  
Jalandhar.

**Note:**

- ☞ The enclosed results pertain only to the sample tested.
- ☞ The report shall not be used for advertising or any legal purpose without written permission from the Head, DWSS.
- ☞ This report cannot be re-produced, except when in full, without the written permission from the Head, DWSS.
- ☞ The sample shall be destroyed after one month from the date of issue of the report.

ID: DWTLJAL/072

Date: 17/03/2022

Sr. No.	Registration No.	District	Block	Name of Place	Sample Receipt Date	Source	Depth	Colour	Taste	Odour	PH	TDS	Turbidity	Total Alkalinity	Total Hardness	Calcium	Magnesium	Chloride	
As per IS 3025:2017 : (Requirement Acceptable Limit-Permissible Limit)																			
						Acceptable Limit			Non-Objectionable	Non-Objectionable	6.5-8.5	500 mg/l	1 NTU	200 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	
						Permissible Limit			Non-Objectionable	Non-Objectionable	No Relaxation	2000 mg/l	5 NTU	600 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	
<b>Test Result :</b>																			
1	DWTLJAL/0322/C/07/2	Jalandhar	Jal West	Dhannal Kalan	17.3.2022	TWELL		2	Agreeable	Agreeable	7.85	360	0.30	264	258	34	42.3	30.0	
2	DWTLJAL/0322/C/07/2	Jalandhar	Jal West	Dhannal Kalan	17.3.2022	RO		4	Agreeable	Agreeable	7.01	148	0.2	150	164	33.66	19.44	22	

  
 Quantity Manager  
 District Water Testing Laboratory,  
 Jalandhar.