

From

Sh. Sujan Singh, IAS,
Deputy Commissioner, Kaithal

To,

Principal,
Akal Academy, Habri,
Tehsil Pundri, Distt. Kaithal.

No. 967 /LFA Dated 24/02/2020

Sub:- Renewal of Fire NOC from fire safety point of view for Akal Academy, Habri, Tehsil Pundri, Distt. Kaithal.

Memo


In view of the satisfactory fire protection system/arrangement mentioned as above, this office has the fire safety certificate for occupation of Building from the fire safety point of view, with the following conditions:-

1. The owner/occupier shall keep duly trained fire staff in all three shifts.
2. The fire protection system tested during inspection shall be maintained properly and always should be in good working condition.
3. If any lapse is found in the protection system at the time of inspection or detected during outbreak of fire action will be taken as per rules against you.
4. You are directed to apply for the fire safety certificate in future before 02 month of expiry of your NOC with information enclosed Performa.
5. The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
6. The owner/occupier shall strictly follow the other applicable rules/regulations/byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms and conditions, you will be liable to be punished as per fire act, 2009 specially chapter-III section 31 sub. section-1 & 2 of fire act 2009.
7. You have to perform quarterly fire drill in your building as pre NBC with intimation to fire department and videography evidence to be kept as a record which shall be produced at the time of next renewal; students/staff should be mentioned in the drill.
8. If the infringements of Byelaws remains un-noticed the Authority reserve the right to amend the fire safety certificate as and when any such Infringements comes to notice giving an opportunity of being

Reminder LFA

heard and the authority shall stand indemnified against any claim on this account.

The above fire safety certificate is valid for only one year from the date of issue of this letter. Applying the fire safety certificate of the same in time shall be responsibility of owner occupier.



for Deputy Commissioner,
Kaithal

Endst. No.

/L.F.A Dated

A copy is forwarded to the following for information and necessary action:-

1. Director, Urban Local Bodies, Haryana, Panchkula.
2. The Fire Officer, Fire Station, Kaithal with reference to their No. FSK/442 dated 01.01.2020.


for Deputy Commissioner,
Kaithal