

**DISTRICT WATER TESTING LABORATORY, GURDASPUR**

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com

Akal Academy Mullianwal  
vill -Mullianwal Dhariwal

No.: DWTLGSP/2223/00302      Dated : 03/04/2023

Subject :      Testing Reports of Water Samples.

Reference:      Your letter/SRF No. AA/M/23/29      Dated: 28/03/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 31/03/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Gurdaspur

D/A :      To Report



Authorized Signatory  
For, District Water Testing Laboratory,  
Gurdaspur

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgspl@gmail.com



## TEST REPORT

Name & Address of Customer : Akai Academy Mullianwal Vill - Mullianwal, Chariwal	Customer Reference No.	No : AA/M/23/29 Dated : 28/03/2023
	Sample Submitted by	Principal
	Date of Sample Receipt	31/03/2023
	Analysis Starting Date	31/03/2023
	Analysis completion Date	01/04/2023

Discipline : Chemical Testing	Group: Water
ULR No.: 00192300000084F	Sample Type : Water
Test Report No.: GSP/2223/00302	Date of Issue : 03/04/2023
Registration no.: DWTLGSP/REG2223/00662	Condition of Sample : Unsealed
Collection Point: Private Submersible	Quantity/Type of Bottle: 1000 ml / Plastic Bottles
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth : Akai Academy Mullianwal / NA
Village : Mullianwal	Habitation : Mullianwal
Block: Chariwal	District : Gurdaspur
Latitude : Not Mentioned	Longitude: Not Mentioned

Sr. No	Part	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1		7.5	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993 ) Electrometric Method
2		1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3		Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4		Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5		320	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6		BDL	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7		160	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8		240	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9		54.50	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	M	25.27	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11		11.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is in accordance with the following terms & Condition :

The results are valid only for the sample as received only.

The sample should be analyzed after retention time unless otherwise specified specially.

This report is for information only and can't be used as evidence in court of law.

Abbreviation: TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected

\* Value not reported for this parameter.

Temperature: 25 ± 5°C and Humidity condition limit: 50 ± 20%

**Mr. Pankaj Kumar**  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory,  
Gurdaspur

----- End of the Test Report -----