

132

AKAL ACADEMY

English Medium, Day Boarding,
Co-Educational Public School

9875987306

e-mail : aaphaphrebhaike@akalacademy.ac.in

Phaphre Bhai Ke, V PO Bhai Behlo Phephre Bhai Ke,
Tehsil & Distt. Mansa (Punjab)-151502


Managed by : The Kalgidhar Trust, Baru Sahib(HP)

Certificate regarding Pure Drinking Water & Hygienic Sanitary Conditions

It is certified that the School has been inspected and the relevant certificate for the same has been issued by the Concerned Department.

Copy of Certificated attached.

Manager


Manager
Akai Academy Phaphre Bhai Ke
(Mansa)


Headmistress

Headmistress
Akai Academy Phaphre Bhai Ke
(Mansa)

AKAL ACADEMY

English Medium, Day Boarding,
Co-Educational Public School

01652-283103

e-mail : principal.phaphrebk@akalacademy.in

Phaphre Bhai Ke, VPO Bhai Behlo Phephre Bhai Ke,
Tehsil & Distt. Mansa (Punjab)-151502
Managed by : The Kalgidhar Trust, Baru Sahib (HP)

103
130
(b)

Certificate of Safe Drinking Water & Hygienic Sanitary Conditions

Certified that proper drinking water Facilities and Hygienic Sanitary Conditions have been provided in the School campus for the students. Certificate issued by the health authorities is attached.

ਮੁੱਖ ਮਾਨਸਾ ਪਬਲਿਕ ਸਕੂਲ
ਜ਼ਿਲ੍ਹਾ ਸਿੱਖਿਆ ਅਫਸਰ (ਜੇ. ਸਿੱ.)
ਮਾਨਸਾ

Manager
Akai Academy Phaphre Bhai Ke
(Mansa)

Headmistress
Akai Academy Phaphre Bhai Ke
(Mansa)

Executive Engineer,
W/S & Sanitation Division No.2, Mansa.
Ph. 01652-230230 E-mail: ee.wss@punjab.gov.in

No 3875

Date: 08/07/2020

To Whom it may concernSAFE DRINKING WATER CERTIFICATE

It is certified that an inspection team headed by Sh. Sukhchain Singh, Junior Engineer & Er. Satish Kumar, Sub-Divisional Engineer (Name of Officers with designation) from W/S & Sanitation S/d Bhikhi at Mansa (Name of Department Office) took the water sample on from Akal Academy, Phephre Bhai Ke, Distt Mansa on 07.07.2020 and after testing found that the Akal Academy, Phephre Bhai Ke, Distt Mansa has safe drinking water & Sanitation facilities for the students and members of staff of the institutions as per report submitted by SDL, WSS S/Div Bhikhi at Mansa.

This Safe Drinking Water & Sanitation Certificate is valid up to
08.07.2021

Signature with Seal:


Name: Er. Ravinder Singh Bansal,

Designation: Executive Engineer,

W/S & Sanitation

Div. No. 2, MANSAL

08/07/2020


Manager
Akal Academy Phaphre Bhai Ke
(Mansa)

Headmistress
Akal Academy Phaphre Bhai Ke
(Mansa)



Report No.-DWTL/MNS/0009/20-21
DISTRICT WATER TESTING LABORATORY
(TECH. MISSION)

WATER SUPPLY AND SANITATION DEPTT. PUNJAB
Water Works Jawaharke, Division No. 1, Mansa
ANALYSIS REPORT FOR PHYSICAL AND CHEMICAL TEST
EXAMINATION OF WATER SAMPLE
email:- dwltmansa@gmail.com

PARTICULARS OF SAMPLE

1. Name **AKAL ACADEMY (Aff.No.MNS005) Phephre Bhai Ke**
2. Block :-
3. District :- **BHIKHI MANSa**
4. Source of sample **RO**
5. Spring level (mt)/ft :-
6. If Whether water chlorination or Not:-
7. Date of collection :- **22-06-20**
8. Name and designation of person collecting sample :- **Smt. Manpreet Kaur Principal**
9. Date of receipt :- **22-06-20**
10. Date of commencing examination :- **24-06-20**

TEST RESULT

		Desirable Limit	Permissible Limit
Colour(Unit on Pt-Co scale)	Colour less	5.0	25
Taste and Odour(Qualitative)	Ordinary		
Total Alkanity(CaCO ₃)mg/l	42	200	600
Calcium(Ca)mg/l	30	75	200
Chlorides(Cl)mg/l	36	250	1000
Fluorides(F)mg/l	0.35	1.00	1.50
Total Hardness(CaCO ₃)mg/l	72	200	600
Iron(Fe)mg/l	0.05	0.3	1.00
Magnesium(Mg)mg/l	24	30	75
PH	7.78	6.5-8.5	8.5
Nitrates(NO ₃)mg/l	10	15	45
Sulphates(SO ₄)mg/l	08	200	400
Total Dissolved Solids(mg/l)	154	500	2000
Turbidity(JTU)	1.12	2.5	10
Residual Chlorine mg/l	-	0.2	0.5
Bacteriological Test			
Coliform Organism MPN/100 m	Not Detected		

REMARKS :-

[Signature]
Manager
Akali Academy Phaphre Bhai Ke
(Mansa)

[Signature]
Chemist
Distt. Water Testing Laboratory
W/S & Sanitation Department
Mansa

1. This report is not for legal purpose.
2. Whole sample consumed in testing
3. Sample not drawn by us unless otherwise stated.

Headmistress
Akali Academy Phaphre Bhai Ke