

Office Executive Engineer, Provincial Division Public Works Building and marg Shakha, Mansa

Telephone/Fax No. 01652-232119

Email-ID ee.pd.mns.pwd@punjab.gov.in
xen.mansa@gmail.com

Letter No. 1110

Date. 19.05.2023

To

The Principal
Akai Academy
Kauriwarra (Mansa)



Subject- Regarding issue of Building Safety Certificate for Session - 2023-24

Reference: - Your Letter No. AAK/06/2023-24 dated 28.04.2023.

Your school building has been inspected by the Sub Divisional Engineer in charge. During the inspection, it was found that your school building is safe. Therefore, keeping in view the recommendation made by the Sub-Divisional Engineer, the School Building Safety Certificate issued for the session 2023-24 (31.03.2024).

**Executive Engineer,
Provincial Board Bh and M
Branch Mansa**

Attested to this copy

SANJAY
NOTARY
Distt. Mansa (Ph)

**Principal
Akai Academy Sr. Sec. School
Kauriwarra, Sardulgarh (Mansa)
(Aff. to CBSE) Aff. No. 163036
School Code-20352**

ਦਫ਼ਤਰ : ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ ਭਵਨ ਤੇ ਮਾਰਗ ਸ਼ਾਖਾ, ਮਾਨਸਾ।

ਟੈਲੀਫੋਨ, ਫੈਕਸ ਨੰ: 01652-232119

Email ID :- xen.mansa@gmail.com

ਪੱਤਰ ਨੰ: 1110

ਮਿਤੀ 19/5/23

ਵੱਲ,

Principal,

Akal Academy Senior Secondary School,

Kauriwarra, Sardulgarh(Mansa)


ਵਿਸ਼ਾ:- ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਸਬੰਧੀ। (ਸਾਲ 2023-24)

ਹਵਾਲਾ:- ਆਪ ਦਾ ਪੱਤਰ ਨੰ. AAK/06/2023-24 ਮਿਤੀ 28/04/2023

ਤੁਹਾਡੇ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਉੱਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਦਫ਼ਤਰ ਵੱਲੋਂ ਨਿਰੀਖਣ ਕੀਤਾ ਗਿਆ। ਨਿਰੀਖਣ ਦੌਰਾਨ ਪਾਇਆ ਗਿਆ ਕਿ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸੇਫ ਹੈ। ਇਸ ਲਈ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਵੱਲੋਂ ਕੀਤੀ ਸਿਫਾਰਸ਼ ਨੂੰ ਮੁੱਖ ਰੱਖਦੇ ਹੋਏ 31/03/2024 ਤੱਕ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/ ਸਰਟੀਫਿਕੇਟ

ਅਤੇ ਨਕਸ਼ਾ


ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਮਾਨਸਾ।


Principal

Akal Academy Sr. Sec. School
Kauriwarra, Sardulgarh (Mansa)
(Aff. to CBSE) Aff. No. 1630367
School Code-20352

Building Safety Report (PART-II)

NAME OF SCHOOL AKAL ACADEMY Kauriwar, Sardulgarh

(District- MANSA)

As per report of Sh. Manjeet Singh Junior Engineer on his visually inspection on dated 15-05-23 above mentioned school seems visually safe subject to the following observations and conditions.

- The Parameters to check the stability and safety of building such as structural Design, Architectural Drawings, Bearing capacity, Foundation details, Structural drawings, Technical Specifications, Test reports of Material used and Quality control reports are not available
- In case any addition, alteration, expansion and modification to this building are required/to be done, regarding this, inspection of undersigned may be arranged and obtained a certification after the completion from the undersigned.
- In the case of building is affected by flood or if there is any settlement of walls foundation of roof etc. immediately inspection of the undersigned arranged to check the stability and safety of the building.
- A separate certificate regarding Fire Fighting should be obtained from the competent Authority.
- A separate certificate regarding Electrical works should be obtained from the competent Authority.
- The owner of the building/Management is fully responsible regarding safety of the building from all angles in spite of this report.
- This report is for the covered area of the school building 7700 Sq.ft which is submitted by the owner of the school building as per drawing.
- The building of the school is constructed as brick masonry.
- This report is not valid for legal purpose.
- That the fee charges for the year 2023-2024 Rs. 15,000/- vide Gr. No. 2843540, 2843551

Dated 04-05-2023 12-05-2023

- Fire safety Certificate is valid till 07-04-2024 and School will be responsible to get renewed fire safety Certificate within time limit.

As per visually inspection as reported by the concerned Junior Engineer the above building may be used for normal use up to 31.03.2024 Subject to the above conditions.

Manjeet
Junior Engineer

Principal
Akhal Academy Sr. Sec. School
Kauriwar, Sardulgarh (Mansa)
(Aff. to CBSE) Aff. No. 1630362
School Code-20352

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ ਨੰਬਰ 2,
ਐ.ਨਿ.ਵਿ.(ਭ ਤੇ ਮ) ਮਾਨਸਾ