

PROFORMA FOR SAFE DRINKING
WATER AND SANITARY CONDITION CERTIFICATE

Ref No./San/2023/16

Dated: 02.05.2023

It is certified that an inspection team headed by Amandeep Singh Epidemiologist and Karaj Singh MPHWS from IDSP Civil Surgeon Office, Tarn Taran inspected the Akal Academy Teja Singh Wala on 28.04.2023, checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 02.05.2024

Signature with Seal: 

Name : Amandeep Singh

Designation : Epidemiologist...

Assistant Engineer of
the Govt. Public Health Department(PHED)/
Authorised officer of the Local Body

Name & Address of the Office /
Department: Civil Surgeon Office, Tarn
Taran

To

Akal Academy Teja Singh Wala
Village Kot Jaspat, Tarn Taran.


Principal
AKAL ACADEMY
Teja Singh Wala, Teh. & Distt
Tarn Taran (Punjab)
CBSE Affiliation No. 163101r


Manager
Akal Academy
Teja Singh Wala (Tarn Taran).

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kaka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl1@gmail.com



IC-10387

TEST REPORT		
Name & Address of Customer : AKAL ACADEMY Teja Singh Wala	Customer Reference No.	No : 1585/121 Dated : 29/03/2023
	Sample Submitted by	Gursharanjit Singh
	Date of Sample Receipt	29/03/2023
	Analysis Starting Date	29/03/2023
	Analysis completion Date	30/03/2023

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC10387230000073F	Sample Type :	Water
Test Report No.:	DWTLTT/2223/00255	Date of Issue :	31/03/2023
Registration no.:	DWTLTT/REG2223/00803	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	2000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village :	Kot Jaspal	Habitation :	Kot Jaspal
Block:	Tarn Taran	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	NA	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	270	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.04	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	220	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	240	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	54.50	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	25.27	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	19.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Principal
AKAL ACADEMY
Teja Singh Wala, Teh. & Dist
Tarn Taran (Punjab)
CBSE Affiliation No. 163101/


Manager
Akal Academy
Teja Singh Wala (Tarn Taran)

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory, Tarn Taran

----- End of the Test Report -----