

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. 926

Dated: 05-06-2024


To

Akal academy

Ubhia,


It is certified that an inspection team headed by :SDE Satinderpal singh & JE Sahil Bansal from: DWSS SUB DIVISION SUNAM inspected the: Akal academy Ubhia on 23-04-2024 and found that the Akal Academy Ubhia has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building &the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of: One year upto 31-03-2025

  
Sub Divisional Engineers,  
W/s and Sanitation Sub Div.

Signature with Seal:.....Sunam.....

Name :Satinderpal singh  
Designation : Sub division Engineer  
Department :DWSS sub division sunam.

  
Manager  
Akal Academy

  
Head Mistress  
AKAL ACADEMY  
UBHIA (Sangrur)

**REGIONAL WATER TESTING LAB, SANGRUR**  
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur  
rwtlsangrur@gmail.com



TC-12990

TEST REPORT			
Name & Address of Customer : <b>AKAL ACADEMY UBHIA VILL-UBHIA,PO-KAUHRIAN,TEHSIL-SUNAM DISTT- SANGRUR</b>		Customer Reference No.	No : A.A.U(2024-25)329 Dated : 18/04/2024
		Sample Submitted by	
		Date of Sample Receipt	18/04/2024
		Analysis Starting Date	18/04/2024
		Analysis completion Date	19/04/2024
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
ULR No.:	TC12990240000067F	Sample Type :	Water
Test Report No.:	RWTL/SNG/2425/00571	Date of Issue :	30/04/2024
Registration no.:	RWTL/SNG/REG2425/00051	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / 730 ft
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Sangrur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.70	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	3	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	139	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	0.90	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	Alkalinity	64	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	Hardness	28	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
8	Calcium	5	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	4	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	24	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

**Manager  
Akal Academy**

Reviewed and Approved By

**Dr. Ramesh Jhorar  
Quality Manager  
Authorized Signatory  
For,Regional Water Testing Lab  
Sangrur**

----- End of the Test Report -----

**Head Mistress  
AKAL ACADEMY  
UBHIA (Sangrur)**

**REGIONAL WATER TESTING LAB, SANGRUR**

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur  
rwtlsangrur@gmail.com

To,

AKAL ACADEMY UBHIA  
VILL-UBHIA, PO-KAUHRIAN, TEHSIL-SUNAM DISTT-SANGRUR


No.: RWTL/SNG/2425/00571 Dated : 30/04/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. A.A.U(2024-25)329 Dated: 18/04/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 18/04/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A : Test Report



Authorized Signatory  
For, Regional Water Testing Lab  
Sangrur



Manager  
Akal Academy



Head Mistress  
AKAL ACADEMY  
UBHIA (Sangrur)