

**OFFICE:- EXECUTIVE ENGINEER, CONSTRUCTION DIVISION NO.1,
PWD (B&R), AMRITSAR**

PHONE :- 0183-2564793

email- xenc1amritsar@yahoo.com

To,

Head Mistress,
Akai Academy,
Basarke, Amritsar.

No. 2017 dated 27-01-2020


Sub:- School Building Safety Certificate upto 01.04.2019 to 31.03.2021 (2 Years)

Ref:- Your letter dated 01-11-2019

The Sub Divisional Engineer, Construction Sub Division No.1, Amritsar vide his office letter No. 479 dated 22.01.2020 has reported this office that Akai Academy, Basarke, Amritsar has been inspected and found the same structurally safe and fit for human inhabitation upto 01.04.2019 to 31.03.2021 (2 Years).

Note:- Certificate from Civil Surgeon / Fire Services must be obtained / renewed every year, otherwise this certificate will not be valid.

DA/ Performa in two parts



Executive Engineer,
Construction Division No.1,
PWD (B&R) Br, Amritsar.

Endst.

No.

A copy of the above is forward to Sub Divisional Engineer, Construction Sub Division No.1, Amritsar with ref. to his office letter No. 479 dt. 22.01.2020 for information.

DA/


Executive Engineer,
Construction Division No.1,
PWD (B&R) Br, Amritsar.

PROFORMA FOR THE SAFETY CERTIFICATE OF SCHOOL BUILDING

(PART-I)

(to be filled in by the Head of school /Institute)

1.	Name of the School	Akal Academy Chheharta Sahib
2.	Location	Village: Basarke, P.O. Gumanpura near Bagichiwala Bhatta, Chheharta Sahib, Amritsar (Punjab)
3.	Plot Area	13694.61 Sq.m.
4.	Plinth Area	809.07 Sq.m.
5.	Number of Storey's	Ground floor, First floor, Second floor
6.	Area of constructed part of the building	25762.02 Sq.ft.
7.	If the building has been constructed under the supervision of the qualified Engineer, the following details may be given: -	2012
a)	Name of Engineer with qualification	En. Sanjeev Dua (B.E. Civil)
b)	Address of the Engineer	H-5A Vijay Nagar New Delhi 110009
c)	If structural drawing used in the construction, if available?	—
d)	Name and address of Architect with qualification	Ranjit Singh Associates, 1206 Suraj Kiran Building
8.	Whether the building has been constructed for the purpose of	
a)	School	Yes /No
b)	Residential purpose and used for a school	Yes /No
9.	Materials used for Roofs	
a)	R.C.C. slabs	✓
b)	R.S.Joists & Battens	—
c)	Wooden Joints and Bottom	—

11/6/12
 Head Mistress
AKAL ACADEMY
 BASARKE, AMRITSAR

10.	Materials used for Walls	
a)	Mud Mortor	Yes /No ✓
b)	Cement Mortor	Yes /No ✓
c)	Lime Mortor	Yes /No ✓
11.	Flooring	
a)	Conglomerate	Yes /No ✓
b)	Terrace	Yes /No ✓
c)	Brick Paving	Yes /No ✓
12.	A detailed drawing indicating the doors along with windows and location fitting and windows is attached.	NO
13.	For Fire Safety	
a)	Whether the width of the staircase is 1.5 mtr.	Yes /No ✓
b)	Whether portable fire extinguisher exists.	Yes /No ✓
c)	Whether school building is free from inflammable & toxic material.	Yes /No ✓
d)	Whether cooking of food is done at a safe place	Yes /No ✓
e)	Whether any Thatch or combustible material has been used.	Yes /No ✓
14.	Requirement for Fire Protection arrangements under NB- Part-IV	
a)	Whether Hose Real provided.	Yes /No ✓
b)	Whether down comer provided	Yes /No ✓
c)	Whether Automatic sprinkler provided	Yes /No ✓
d)	Whether underground static water storage tank of capacity 5000 Ltr. (if converted area exceeds 1500 sqm)	Yes /No ✓
e)	Whether over head tank of capacity 10000 Ltr. Exists (in case of hose real) 20000 Ltr.	Yes /No ✓
f)	Whether one eclectic and on diesel pump of 3 Kg/cum pressure of capacity 1620 LPM, one electric pump of Capacity 180 LPK exist near underground static tank.	Yes /No ✓
g)	Whether a pump 3 kg/cum pressure & 450/500 LPM exist near over head tank.	Yes /No ✓

Signature of the Head of School /Institute.

Prabhat
7/6/19
Headmistress
AKAL ACADEMY
BASARKE, AMRITSAR

(PART-II)
[to be filled in by the Sub Division Engineer of P.W.D. (B&R) Department]

[to be filled in by the Sub Division Engineer of P.W.D. (B&R) Department]

- [illegible]

Sub Divisional Engineer,
Constn. Sub Divn. No. 1,
BMD S&P A. m. t.